

Beech Creek Septic & Excavating
10970 FM 1013 RD.
Hillister, TX 77624

(409) 429-0589

Printed:9/18/2025

Insp ID #:429

Permit #: **229-3752**

To: Kameron & Stephanie Perry
2394 CR 1520
Warren, TX 77664

Main Phone:

Work:

Cell Phone:

Alt Cell:

Customer ID: 44

Contract Dates: 10/4/2023 - 10/4/2025

Scheduled Date: 10/4/2025

Inspection 6 of 6

Aerator: 500 N, NC, NU

Installed: 10/4/2023

Aerator S/N: 23010321

Warranty End: 10/4/2025

Site: 2394 CR 1520, Warren, TX 77664

Agency: TCEQ Beaumont

County:

Mfg / Brand: - CLEARSTREAM

Treatment Type: Aerobic

System S/N: 21712-555

Disposal: Surface Application

Service Type:**Scheduled Inspection**

☒ This counts as a type of "Scheduled Inspection"

Visit Date:**9/18/2025**

Time In:

Method:**Grab**

Technician:Not Assigned

Maint. Provider:Shawn Bible

Entered By:_

Aerators: Operational

Filters: Operational

Irrigation Pumps: Operational

Disinfection Device: Operational

Chlorine Supply: Operational

Chlorine Residual: .0

Sludge Levels

For Tank 1: 3

For Tank 2: 18

Floats: OP

Timer: OP

Electric Circuits: Operational

Distribution System: Operational

Sprayfield Veg: Operational

Tank Lid / Riser: Secured

Insp. Port / Plug: Secured

Alarm: Operational

Comments

☒ **Service Completed**

- Technician Secured the Tank Lid and/or Riser prior to leaving location. - Inspection Port Plug was noted as Secured prior to leaving.
Replaced Both Spray Heads. - Copy emailed to the customer on 9/18/2025.

Site: 2394 CR 1520, Warren, TX 77664

Originally Entered On: 9/18/2025

License Info: 2392 Expires: 1/31/2028